

Regarding Approval LA24002
SE 21-9-26 W4M

Water Well Monitoring Requirements

The purpose of this statement is to outline the water well monitoring requirements for Approval LA24002. Operating Condition #24 of Approval LA24002 reads:

“The permit holder shall sample and test raw groundwater from water well #9731008, according to water well monitoring requirements prescribed by the NRCB in writing. The NRCB may, based on the monitoring results and at its discretion, revise those requirements from time to time, in writing.”

The NRCB has determined that the water well monitoring requirements for this facility should be remain as follows:

Monitoring Frequency

Annually, with results submitted to the NRCB by July 31 of each year

Water Well Test Parameters

Chlorides and nitrate-nitrogen

Water Wells to be used for Monitoring

#9731008

These monitoring requirements become effective on the date of this letter and supersede any previously issued monitoring requirements at this facility.

July 23, 2024



Kelsey Peddle
Approval Officer